



April 12, 2024

RANDOLPH WATER WORKS
ATTN MARY KING CITY CLERK
PO BOX 88
RANDOLPH IA 51649

Subject: Approval of Preliminary Engineering Report for Water Source, Treatment, Storage and Distribution System

PWSID No. IA3649072; Project No. W2024-0119; SRF Project No. FS-36-24-DWSRF-044

Dear Ms. King:

We have completed our review of the preliminary engineering report titled "Preliminary Engineering Report, Revision 2 - Water Source, Treatment, Storage and Distribution System" prepared by SEH dated April 2024. We are in general agreement with the concepts, conclusions, and recommendations contained in this report regarding the Water System Improvements to include well replacement of Well #4; water plant rehabilitation; construction of a new 30,000-gallon elevated water tower (or rehabilitation of existing standpipe); replacement of existing water main on Randolph St; replacement of remaining 6-inch cast iron watermain with 6-inch PVC watermain; and replacement of water meters, with the following comment:

1. The current and projected water demands seem excessive for the city's population size. It is recommended that the City reexamine their water demands and reduce water losses or unaccounted water if any.

This preliminary engineering report approval is not considered an approval of a Drinking Water State Revolving Fund loan or project eligibility.

In accordance with the rules of this department, plans and specifications for the proposed improvements must be in concurrence with the preliminary engineering report as accepted. Any deviation from the design as outlined in the engineering report must be identified and accompanied by an explanation detailing the reasons for modification.

If you have any questions, please contact Timothy Duda, via e-mail at timothy.duda@dnr.iowa.gov or by telephone at 515-829-9046

Sincerely,

Timothy Duda
Environmental Engineer
Water Supply Engineering

cc: Ben Klaus, SEH Inc, 5414 NW 88 St Ste 140, Johnston IA 50131-1701
 Tracy Scebold, Iowa Finance Authority, 1963 Bell Ave Ste 200, Des Moines IA 50315
 Iowa DNR SRF Program – Anthony Shellenberger

- Field Office No. 4 – Atlantic
- File: PWSID No. IA3649072 (green folder)
- File: SRF No. FS-36-24-DWSRF-044